



GENERAL NOTES:

1. PRECAST REINFORCED CONCRETE RISERS, TOP AND BOTTOM SHALL CONFORM TO ASTM C-478.
2. WHERE REQUIRED, WATERPROOF FRAMES SHALL BE NEENAH R-1919 W/ LID AS ABOVE OR APPROVED EQUAL.
3. THE SPACE BETWEEN THE CONE, ADJUSTING RINGS AND FRAME SHALL BE COMPLETELY SEALED WITH PREFORMED BITUMINOUS MASTIC GASKET.

GREASE TRAP CATCH BASIN
DETAIL (1,000 GAL.)
 DOWNERS GROVE SANITARY DISTRICT

REV. 2-1-15