



GENERAL NOTES:

1. PRECAST REINFORCED CONCRETE SHALL CONFORM TO ASTM C-478.
2. WHERE REQUIRED, WATERPROOF FRAMES SHALL BE NEENAH R-1919 W/ LID AS ABOVE OR APPROVED EQUAL.
3. THE SPACE BETWEEN THE TOP, CONCRETE COLLAR AND FRAME SHALL BE COMPLETELY SEALED WITH PREFORMED BITUMINOUS MASTIC GASKET.
4. THE PLUMBING CONTRACTOR SHALL PROVIDE COMPLETE WATER CHARGE OF GREASE TRAP.

GREASE TRAP DETAIL (1800 GAL.)

DOWNERS GROVE SANITARY DISTRICT

REV. 2-1-15