

NOTES:

- 1. THIS DETAIL TO ONLY BE USED IN THOSE INSTANCES WHERE THE FIRST FLOOR WOULD OTHERWISE HAVE TO BE PUMPED TO THE SEWER.
- 2. RIM ELEVATION OF THIS STRUCTURE MUST BE LOWER THAN THE RIM ELEVATION OF THE NEAREST DISTRICT UPSTREAM MANHOLE.
- 3. RIM ELEVATION OF THIS STRUCTURE MUST BE ONE FOOT ABOVE THE 100 YEAR FLOOD ELEVATION.
- * OPTIONAL PIPE 18-INCH DIAMETER HDPE ADS N-12 ST IB PIPE AND EAST JORDAN FRAME AND COVER #2890

PRESSURE RELIEF CLEANOUT STRUCTURE DETAIL

DOWNERS GROVE SANITARY DISTRICT NO SCALE



REV. 6-21-05 REV. 2-1-15

REV. 8-11-15